




序号	报告编号	发布日期	结论	影像资料
77	GX-B1328/20-5-24001	2024/2/6	本次共检绝缘手套196只，196只绝缘手套合格。	
78	GX-B1328/20-5-24002	2024/2/6	本次共检绝缘鞋126只，126只绝缘鞋合格。	
79	GX-B1328/20-5-24003	2024/2/6	本次共检验电器55套，55套验电器合格。	

80	GX-B1328/20-5-24004	2024/2/6	本次共检便携式接地和接地短路装置56套，56套便携式接地和接地短路装置合格。		
81	GX-B1328/20-5-24005	2024/2/6	本次共检绝缘杆6支，6支绝缘杆合格。		
82	GX-B1328/20-5-24006	2024/2/6	本次共检绝缘胶垫146个，146个绝缘胶垫合格。		

83	GX-B1309/21-5-24003	2024. 2. 7	合格	
84	GX-B1500/21-5-24015	2024. 2. 7	合格	
85	GX-B1500/21-5-24016	2024. 2. 7	合格	

86	GX-B1500/21-5-24017	2024. 2. 7	合格			
87	GX-B1500/21-5-24018	2024. 2. 7	合格			
88	GX-B1500/21-5-24019	2024. 2. 7	合格			

89	GX-B1309/21-5-24004	2024. 2. 7	合格	
90	GX-B1500/21-5-24020	2024. 2. 7	合格	
91	GX-B1500/21-5-24021	2024. 2. 7	合格	

92	GX-B1500/21-5-24022	2024. 2. 7	合格			
93	GX-B1500/21-5-24023	2024. 2. 7	合格			
94	GX-B1500/21-5-24024	2024. 2. 7	合格			

95	GX-B1310/21-5-24034	2024/2/4	符合标准要求。		 <p>2024/1/23</p>	
96	GX-B1404/20-5-24001	2024/2/18	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。		 <p>2024/01/23</p>	
97	GX-B1404/20-5-24002	2024/2/18	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。		 <p>2024/01/23</p>	

98	GX-B1404/20-5-24003	2024/2/18	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。	
99	GX-B1404/20-5-24004	2024/2/18	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。	
100	GX-B1404/20-5-24005	2024/2/18	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。	

101	GX-B1404/20-5-24006	2024/2/18	<p>所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。</p>			
102	GX-B1404/20-5-24007	2024/2/18	<p>所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。</p>			
103	GX-B1404/20-5-24008	2024/2/18	<p>所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。</p>			

104	GX-B1358/21-5-24001	2024. 2. 21	详见检验结果。	
-----	---------------------	-------------	---------	---