




序号	报告编号	发布日期	结论	影像资料
80	GX-B1404/20-6-24015	2024/8/15	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。	
81	GX-B1404/20-6-24016	2024/8/15	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。	

82	GX-B1404/20-6-24017	2024/8/15	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。	
83	GX-B1404/20-6-24018	2024/8/15	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。	
84	GX-B1415/22-6-24006	2024/8/21	综合判定：合格	

85	GX-B1535/21-6-24002	2024/8/20	除驱动轮直径与钢丝绳中最粗钢丝的直径之比小于900外，其余所检项目合格。	
86	GX-B1310/21-6-24210	2024/8/6	符合标准要求	
87	GX-B1310/21-6-24211	2024/8/6	符合标准要求	

88	GX-B1310/21-6-24212	2024/8/6	符合标准要求		
89	GX-B1310/21-6-24213	2024/8/6	符合标准要求		
90	GX-B1310/21-6-24214	2024/8/6	符合标准要求		

91	GX-B1310/21-6-24215	2024/8/6	符合标准要求	
92	GX-B1310/21-6-24216	2024/8/6	符合标准要求	
93	GX-B1310/21-6-24217	2024/8/6	符合标准要求	

94	GX-B1310/21-6-24218	2024/8/6	符合标准要求	
95	GX-B1310/21-6-24219	2024/8/6	符合标准要求	
96	GX-B1310/21-6-24220	2024/8/6	符合标准要求	

97	GX-B1310/21-6-24221	2024/8/6	符合标准要求	
98	GX-B1310/21-6-24222	2024/8/6	符合标准要求	